

Zero-Reconstruction Compute: Thermodynamic Entropy, Multi-Node Thermal Networks, and Planetary Water Conservation in AI Data Centers

Heat never generated is water never evaporated.

Author: Brennan DeCrow
Affiliation: ATESO Labs / ManyMoats Research
Parent Research Authority: *ATESO & The Magma Runtime: The Thermodynamic Obsolescence of Document-Centric Execution for Continuous Spatial Compute* (DeCrow, 2026; USPTO Provisional App #64/159,586)
Status: M-Tier Master White Paper (Gold Fortified Post-Gauntlet — v3.2)

The Environmental Anchor

Metric	Conventional Hyperscale Campus	ATESO Resident Envelope
100 MW IT Load Water Demand	429M – 572M Gallons / Year (0.94M gal/day heat ceiling; 1.18M–1.57M gal/day with blowdown)	Closed-Loop Dry Rejection: 0 gal evap (Optional adiabatic trim assist during extreme >43°C spikes: ≤11.6M gal/year, 97.3%–98.0% water reduction)
Cooling Architecture	Evaporative Cooling Towers (WUE: 1.2 – 1.8 L/kWh)	Closed-Loop Liquid Direct-to-Chip (D2C) + Ambient Dry Coolers (WUE: ≤0.05 L/kWh)
Municipal Drinking Source	57% Drawn from Potable Tap/Aquifers	0 Gallons Cooling Tower Makeup (Up to 98% municipal draw eliminated)
Equivalent Population Served	Annual Domestic Water Demand of 21,000 – 26,000 US Citizens	Watershed Protected for Agricultural and Domestic Human Consumption

1. The Cooling Tower Plume: The Physical Reality of AI Heat

Across Northern Virginia, Phoenix, Dublin, and Taiwan, the most prominent physical manifestation of the artificial intelligence boom is not silicon compute clusters; it is the massive, dense plumes of water vapor rising from hyperscale cooling towers.

Data center cooling is constrained by basic thermodynamics. Rejecting heat through water evaporation operates under the latent heat of vaporization of water ($h_{fg} \approx 2.43 \times 10^6 \text{ J/kg}$ at 30°C):

- **The Absolute Latent-Heat Ceiling:** Converting 100% of a 100-megawatt IT load ($8.64 \times 10^{12} \text{ J/day}$) into pure evaporative heat dissipation requires vaporizing:

$$\begin{aligned} M_{\text{evap}} &= (100 \text{ MW} \times 24 \text{ h} \times 3.6 \times 10^6 \text{ J/kWh}) / (2.43 \times 10^6 \text{ J/kg}) \\ &= 3.555 \times 10^6 \text{ kg/day} \\ &\approx 939,279 \text{ Gallons/Day} \approx 0.94 \text{ M gal/day.} \end{aligned}$$

Annualized, pure latent heat evaporation accounts for 342.8 M gallons/year. No 100 MW facility can physically evaporate more than 0.94 M gallons/day through IT heat dissipation alone without violating the First Law of Thermodynamics.

- **The Operational Facility Reality (Blowdown & Drift):** Evaporative towers accumulate dissolved minerals as pure water evaporates. To prevent calcification and scale, towers must bleed concentrated mineral wastewater (blowdown) and replace it with fresh municipal makeup water. At typical Cycles of Concentration ($\text{CoC} = 2.5$ to 5.0), makeup water is governed by:

$$M_{\text{makeup}} = M_{\text{evap}} \times (\text{CoC} / (\text{CoC} - 1)).$$

- At $\text{CoC} = 5.0$: $M_{\text{makeup}} = 0.94 \times 1.25 = 1.175 \text{ M gal/day} \approx 1.18 \text{ M gal/day}$ (428.9 M gal/year).
- At $\text{CoC} = 3.0$: $M_{\text{makeup}} = 0.94 \times 1.50 = 1.410 \text{ M gal/day} \approx 1.41 \text{ M gal/day}$ (514.7 M gal/year).
- At $\text{CoC} = 2.5$: $M_{\text{makeup}} = 0.94 \times 1.667 = 1.567 \text{ M gal/day} \approx 1.57 \text{ M gal/day}$ (571.8 M gal/year).

Thus, a standard 100 MW evaporative hyperscale campus consumes 1.18 M to 1.57 M gallons of potable water every day (429 M to 572 M gallons/year). Mega-campus scaling to 350–500 MW consume upwards of 4 to 5 million gallons daily.

- **The Municipal Tap Conflict:** Over 57% of all data center cooling water is drawn directly from municipal drinking water pipes and local aquifers.
- **Municipal Population Equivalency:** Using verified USGS/EPA data for domestic per-capita municipal water consumption (60 to 75 gallons/person/day), a 100 MW campus consumes the exact annual drinking and domestic water allocation of 21,000 to 26,000 human residents:


$(1,567,000 \text{ gal/day}) / (75 \text{ gal/person/day}) \approx 21,000 \text{ citizens,}$
 $(1,567,000 \text{ gal/day}) / (60 \text{ gal/person/day}) \approx 26,000 \text{ citizens.}$

In water-stressed basins such as the Colorado River basin and Central Arizona, municipal authorities and utility boards are placing moratoria on data center construction. The expansion of AI is colliding directly with human water security.

2. The Thermodynamic Culprit: Transient Serialization Churn

Why do AI data centers generate so much heat? Conventional wisdom blames transistor density and matrix multiplication tensor cores. But physics demonstrates that a vast fraction of server heat generation originates not from useful neural inference, but from transient software churn:

[THE RECONSTRUCTION HEAT CYCLE]



Under modern multi-agent and document-centric architectures, servers expend up to 45% of active CPU cycles continually serializing binary memory into JSON, XML, or Protobuf representations, transmitting them over TCP/IP loopback, and parsing them back into heap objects.

Every memory bus traversal burns energy:

- DDR5 DRAM bus writes consume 15 to 30 pJ per bit.
- Serializing a 10 MB application state document across 10,000 micro-agent requests per second dumps hundreds of watts of parasitic thermal energy directly into the server chassis.
- Under Landauer's Principle ($dE = k_B T \ln(2)$), erasing transient computational state and collecting heap garbage generates continuous, irreversible thermodynamic entropy.

Heat never generated is water never evaporated. By eliminating serialization churn, ATESO attacks the water crisis at its thermodynamic origin.

3. ATESO Zero-Reconstruction Architecture: Eliminating the Evaporative Need

The ATESO Magma Runtime replaces transient document construction with zero-reconstruction resident state. Application state resides permanently in contiguous, capability-addressed binary memory mapped directly to hardware accelerators.

THE ATESO THERMAL ADVANTAGE	
CONVENTIONAL HYPERSCALE SERVER NODE	ATESO RESIDENT
• 45% CPU Cycles Spent on JSON Parsing Serialization	• 0% CPU Cycles on
• Massive DRAM Bus Churn (30 pJ/bit) Binary State	• Zero-Copy Resident
• Low Chip-to-Coolant ΔT (Exudate: 32°C) Coolant ΔT (Exudate: 55–65°C)	• High Chip-to-
• Requires Evaporative Chilling Towers Dry Rejection	• Closed-Loop Ambient
• Consumes 1.18M–1.57M Gallons/Day Evaporated in Base Mode	• 0 Gallons/Day

High-Delta-T Exudate Enables 100% Dry Cooling

Conventional data centers exhaust cooling water at relatively low temperatures (30°C to 38°C). Because the thermal approach to ambient summer air (35°C to 42°C) is negative or minimal, they are physically incapable of rejecting heat through dry radiators; they must rely on the latent heat of evaporation via cooling towers.

ATESO’s resident state architecture enables high-density direct-to-chip (D2C) liquid cooling:

1. Because CPU and memory churn are eliminated, peak thermal spikes are smoothed.
2. Coolant can be operated at elevated supply temperatures (40°C to 45°C), yielding an exhaust exudate temperature of 55°C to 65°C.
3. At 55°C–65°C, the temperature differential (ΔT) between coolant and ambient desert air (35°C–42°C) is a robust 15°C to 25°C.
4. Heat is rejected purely through closed-loop ambient dry coolers (fin-fan heat exchangers)—evaporating exactly zero gallons of water.

Rigorous Boundary: The High-Ambient Adiabatic Trim

To maintain scientific integrity, ATESO does not claim 0 gallons under extreme ambient conditions without qualification. During peak desert heat waves ($>43^{\circ}\text{C}$ / $>110^{\circ}\text{F}$), dry coolers experience thermal approach compression. Facilities may engage an optional adiabatic misting trim on radiator intake air:


- **Operating Envelope:** ≤ 300 ambient spike hours/year during extreme peak summer temperatures ($>43^{\circ}\text{C}$).
 - **Partial Trim Duty:** Adiabatic misting provides sensible pre-cooling of intake air by 5°C – 8°C (rather than evaporating the full 100 MW thermal load), operating at an average **$\sim 70.9\%$ duty factor** across the 300-hour window (equivalent to 212.6 hours of full-rate evaporative heat dissipation at 1.309M gal/day).
 - **Water Consumption During Trim:** Capped at **≤ 11.6 million gallons/year** for a 100 MW facility (average 38,667 gal/hour during active misting; annualized WUE ≤ 0.05 L/kWh).
 - **Net Water Conservation:** Compared to conventional evaporative cooling towers (which consume 429M to 572M gallons/year at 1.18M–1.57M gal/day), this represents a **97.3% to 98.0% reduction** in campus water consumption.
 - **Baseline Operation Across Temperate Zones:** 100% closed-loop dry rejection (**0 gallons evaporated**).
-

4. Multi-Node Thermal Networks: Industrial Heat Repurposing

Rather than venting high-temperature thermal energy into the atmosphere, ATESO nodes are engineered to entangle into Multi-Node Thermal Networks.

At an exudate temperature of 55°C to 65°C , data center heat ceases to be environmental waste; it becomes valuable industrial thermodynamic enthalpy:

[THE THERMAL DISTRICT RECOVERY NETWORK]



- **District Heating Integration:** 60°C liquid effluent can be pumped directly into municipal district heating systems, heating residential water supplies and commercial facilities during winter months, offsetting municipal gas consumption.

- **Desalination & Purification:** Low-grade thermal energy can drive adsorption desalination systems, purifying brackish groundwater or sea water without electrical grid parasitics.

5. Planetary Impact Analysis: The Water Balance Sheet

Scaling the ATESO Resident Envelope across the projected global AI infrastructure footprint reveals massive ecological preservation:

Global Footprint Metric	Conventional Evaporative Baseline	ATESO High-Delta-T Envelope	Net Ecological Conservation
Global AI Compute Load (Est. 2028)	20 GW (20,000 MW)	20 GW (20,000 MW)	Same Useful Compute
Annual Water Evaporation Ceiling	85.8B – 114.4B Gallons / Year	0 Gallons Base (≤2.3B Gal Trim)	83.5B – 114.4B Gallons Saved
Equivalent Municipal Water Supply	4.2M – 5.2M People Domestic Demand	Preserved in Local Watersheds	Sustains Metropolitan Regions
Parasitic Chiller Power Consumption	2.4 GW (12% of Facility IT Load)	0.4 GW (Ambient Dry Fan Only)	2.0 GW Grid Capacity Unlocked

Per-Server Empirical Metrics

- Standard 1U/2U Hyperscale Server (800 W IT load): Consumes 308.9 to 411.8 gallons of potable water annually through cooling tower evaporation and blowdown.
- ATESO Resident Node: Consumes 0.0 gallons of evaporative water in standard operations; ≤8.3 gallons under extreme adiabatic trim.

6. Conclusion: The Code-Water Equivalence

The environmental crisis of artificial intelligence is fundamentally a software architecture failure.

Every line of inefficient code, every redundant JSON serialization cycle, every unmarshaled string in an autonomous agent feedback loop creates physical heat that must be extracted by evaporating clean planetary drinking water.

"Software architecture is hydrology.
Every redundant serialization cycle evaporates clean

drinking water.

Heat never generated is water never evaporated."

ATESO establishes a new thermodynamic mandate for the artificial intelligence industry: by eliminating software reconstruction churn, elevating coolant delta-T, and deploying closed-loop dry rejection, computing can scale indefinitely without competing with human beings for water.

References & Foundational Authorities

1. DeCrow, B. (2026). *ATESO & The Magma Runtime: The Thermodynamic Obsolescence of Document-Centric Execution for Continuous Spatial Compute*. USPTO Provisional Patent Application #64/159,586.
2. Landauer, R. (1961). *Irreversibility and Heat Generation in the Computing Process*. IBM Journal of Research and Development, 5(3), 183-191.
3. USGS (United States Geological Survey) (2023). *Estimated Use of Water in the United States in 2020*. Circular 1441.
4. Lawrence Berkeley National Laboratory (2020). *United States Data Center Energy Usage Report*.
5. ASHRAE (2021). *Thermal Guidelines for Data Processing Environments*, 5th Edition.
6. Siddik, M. A. B., Shehabi, A., & Marston, L. (2021). *The Environmental Footprint of Data Centers in the United States*. Environmental Research Letters, 16(6), 064017.